



Certificate of Compliance

Certificate: 1706447 (LR 110441-1)

Master Contract: 187789

Project: 2712700

Date Issued: May 12, 2014

Issued to: Keyscan Inc.

901 Burns St E
Whitby, ON L1N 6A6
Canada
Attention: Robert Taylor

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Grace Gao

Issued by: Grace Gao

PRODUCTS

CLASS 4812 05 - SIGNAL APPLIANCES - Systems

CLASS 4812 85 - SIGNAL APPLIANCES - Signaling Systems - Certified to US Standards

Access control systems, Keyscan Models CA250, CA4500, CA8500 , EC1500 , EC2500 , 16V ac, 40VA, Class 2 input; relay output contacts, 24V ac, 10A; 30V dc, 5A.

Notes:

Access Control System, Class I as per UL 294, Fifth Ed.

APPLICABLE REQUIREMENTS

CSA Std C22.2 No.205-12 - Signal Equipment

UL Std No.294, Fifth Ed. - Access Control System Units



Supplement to Certificate of Compliance

Certificate: 1706447

Master Contract: 187789

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
2712700	May 12, 2014	Update report for minor alternate component and standard edition upgrade
2445867	Aug 30, 2011	Add new model designations.
2085275	Dec 5, 2008	Revised component layout and firmware of CA Series and add Models EC1000 and EC2000.
1706447	Sep 7, 2005	Report correction. Supercedes report LR 110441-1

History

LR 110441-1 97/11/07 Original Certification.